

Prüfinstitut:  
I.F.I., Institut für  
Industrieaerodynamik GmbH

Anschrift:  
Welkenrather Straße 120  
D-52074 Aachen

Prüfungsleitung:  
Dipl.-Ing. B. Konrath

Institutsleitung:  
Dipl.-Ing. B. Konrath  
Dipl.-Ing. R.-D. Lieb

## Type testing of a VAV- system according to DIN EN 14 175-6:2006



I.F.I. Institut für  
Industrieaerodynamik GmbH  
Institut an der  
Fachhochschule Aachen

### Certificate No. 1/TVR-250/07/07

#### VAV-System:

Designation : **TROX TVR/250/TRA/FH**  
Type : TROX Labcontrol TCU II  
Diameter : 250 mm  
Range VAV : 445–2214 m<sup>3</sup>/h  
Range press. :  $\Delta p_{\min} = 20 \text{ Pa}$  (445 m<sup>3</sup>/h),  $45 \text{ Pa}$  (2214 m<sup>3</sup>/h)  
 $\Delta p_{\max} = 1000 \text{ Pa}$  (445 m<sup>3</sup>/h, 2214 m<sup>3</sup>/h)  
Manufacturer: Trox GmbH  
Address : Heinrich-Trox-Platz  
D-47504 Neukirchen-Vluyn

**Max. nominal extract air volume rate** : 2214 m<sup>3</sup>/h  
**Min. nominal extract air volume rate** : 445 m<sup>3</sup>/h  
**Tested extract air volume rates** : 2214-1200-445 m<sup>3</sup>/h  
**Date of testing** : 06.03.-22.07.2007

The variabel air volume system **TROX TVR/250/TRA/FH** has been subjected to a type examination test for variabel air volume fume cupboards according to DIN EN 14 175-6 of August 2006. The air flow rate characteristics, the dynamic control modes and the setpoint values of the VAV-systems have been tested according to the requirements of DIN EN 14175-6:2006 at the above mentioned extract air volume flow rates.

The tested variabel air volume system **TROX TVR/250/TRA/FH** is in accordance with DIN EN 14175-6:2006.

The detailed results and test conditions of the type examination test of the variable air volume systems are given in „Test report No. 1/TVR-250/07/07“.

**Date of issue: 23.08.2007**

**Head of test station:**

Dipl.-Ing. B. Konrath

**Test station:**

I.F.I. Institut für  
Industrieaerodynamik GmbH  
Institut an der  
Fachhochschule Aachen  
Welkenrather Str. 120  
D-52074 Aachen



**Responsible test engineer:**

M. Winklehner